

Annual
WATER
QUALITY
REPORT
Reporting Year 2012



PWS ID#: 0430042

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (972) 468-4100.

There When You Need Us

We are once again proud to present our annual water quality report covering all testing performed between January 1 and December 31, 2012. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users.

Please remember that we are always available to assist you should you ever have any questions or concerns about your water.

Water Conservation

You can play a role in conserving water and save yourself money in the process by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

Community Participation

You are invited to participate in our regular public forums and voice your concerns about your drinking water. The City Council meets the first and third Tuesday of each month, beginning at 6 p.m., at City Hall, Council Chambers, 206 North Murphy Road, Murphy, Texas.

Substances That Could Be in Water

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include: **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife; **Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; **Pesticides and Herbicides**, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses; **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and which may also come from gas stations, urban stormwater runoff, and septic systems; **Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact our business office. For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation, and public health. Also, the TCEQ has a Web site (www.tceq.com) that provides complete and current information on water issues in Texas, including valuable information about our watershed.

Impact of Zebra Mussels

The zebra mussel is a small mussel native to Russia. In 1988, it reached North America by a transatlantic freighter. Since then, they have continued to spread throughout the country. Zebra mussels are very successful invaders because they live and feed in many different aquatic habitats and breed prolifically (each female produces 1 million eggs per year) for their entire five-year lifespan.

Adult zebra mussels colonize on living and non-living surfaces, including boats, buoys, piers, plants, and clams. They are a great concern to drinking water utilities because they can attach to water intake pipes, severely restricting the flow of fresh water. They can also impact water quality by increasing taste-and-odor problems in the water supply.

Zebra mussels are almost impossible to eradicate once they become established. Water utilities have had to retool their water intake systems to prevent zebra mussel-related problems costing millions of dollars a year. Utilities rely on a variety of methods to remove mussels from intake pipes; since there is no single, ideal removal solution, new methods are constantly under investigation.

While complete removal may be impossible, preventing zebra mussel spread is not. Human activities have spread them into many inland lakes and streams, usually through recreational boating, fishing, and diving practices. Simple steps such as draining live wells, cleaning vegetation off boat trailers, removing attached zebra mussels from boat hulls, and not dumping bait into lakes or rivers can prevent the spread of zebra mussels into non-infested waters.

QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call Customer Service at (972) 468-4100 or send an email to customerservice@murphytx.org.

What's Your Water Footprint?

You may have some understanding about your carbon footprint, but how much do you know about your water footprint? The water footprint of an individual, community, or business is defined as the total volume of freshwater that is used to produce the goods and services that are consumed by the individual or community or produced by the business. For example, 11 gallons of water are needed to irrigate and wash the fruit in one half-gallon container of orange juice. Thirty-seven gallons of water are used to grow, produce, package, and ship the beans in that morning cup of coffee. Two hundred and sixty-four gallons of water are required to produce one quart of milk, and 4,200 gallons of water are required to produce two pounds of beef.

According to the U.S. EPA, the average American uses over 180 gallons of water daily. In fact, in the developed world, one flush of a toilet uses as much water as the average person in the developing world allocates for an entire day's cooking, washing, cleaning, and drinking. The annual American per capita water footprint is about 8,000 cubic feet; twice the global per capita average. With water use increasing six-fold in the past century, our demands for freshwater are rapidly outstripping what the planet can replenish.

To check out your own water footprint, go to www.h2oconserve.org, or visit www.waterfootprint.org to see how the water footprints of other nations compare.

Important Health Information

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Where Does My Water Come From?

The City of Murphy and 60 other North Texas communities receive drinking water from the North Texas Municipal Water District (NTMWD). More than 1.6 million citizens rely on the treated water supply provided by the NTMWD. Murphy's water is mainly from Lavon Lake. The NTMWD Water Treatment Plants are in Wylie, Texas. These treatment facilities provide billions of gallons of clean drinking water every year to their area customers, like the City of Murphy. Lavon Lake serves as the NTMWD's main raw water supply source, with the NTMWD holding water rights in the reservoir. Lavon Lake also serves as a terminal reservoir for additional supplies that are transferred to the reservoir to augment supplies from Lake Texoma, Jim Chapman Lake, Lake Bonham, and the East Fork Wetland Project. Additional supplies are available through a contract with the SRA, providing for water transfer to Lavon Lake from Lake Tawakoni and from a contract with the Greater Texoma Utility Authority for additional supplies from Lake Texoma.

Water Treatment Process

The treatment process consists of a series of steps. First, raw water is drawn from our water source and sent to an aeration tank, which allows for oxidation of the high iron levels that are present in the water. The water then goes to a mixing tank where polyaluminum chloride and soda ash are added. The addition of these substances causes small particles to adhere to one another (called flocculation), making them heavy enough to settle into a basin from which sediment is removed. Chlorine is then added for disinfection. At this point, the water is filtered through layers of fine coal and silicate sand. As smaller, suspended particles are removed, turbidity disappears and clear water emerges.

Chlorine is added again as a precaution against any bacteria that may still be present. (We carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste.) Finally, soda ash (used to adjust the final pH and alkalinity), fluoride (used to prevent tooth decay), and a corrosion inhibitor (used to protect distribution system pipes) are added before the water is pumped to sanitized underground reservoirs, water towers, and into your home or business.



What is the typical per-day water usage?

While usage varies from community to community and person to person, on average, Americans use 183 gallons of water a day for cooking, washing, flushing, and watering purposes. The average family turns on the tap between 70 and 100 times daily. About 74% of home water usage occurs in the bathroom, about 21% in the laundry room, and about 5% in the kitchen.

Why do water pipes tend to break in winter?

Liquids generally contract when frozen and become more dense; however, the unique qualities of water cause it to expand by up to 9% when it freezes. That is why water pipes burst when temperatures reach the freezing mark.

How much water is used to create the food we eat each year?

The average American consumes 1,500 pounds of food each year; 1,000 gallons of water are required to grow and process each pound of that food. Thus, 1.5 million gallons of water is invested in the food eaten annually by just one person! This 200,000-plus cubic feet of water per person is enough to cover a football field four feet deep.

Is it okay to use hot water from the tap for cooking and drinking?

No, ALWAYS use cold water. Hot water is more likely to contain rust, copper, and lead from household plumbing and water heaters. These harmful substances can dissolve into hot water faster than they do into cold water, especially when the faucet has not been used for an extended period of time.

What type of container is best for storing water?

Consumer Reports has consistently advised that glass or BPA-free plastics such as polyethylene are the safest choices. To be on the safe side, do not use any container with markings on the recycle symbol showing 7 PC (which is the code for BPA). You could also consider using stainless steel or aluminum containers that have BPA-free liners.

How much water is used in the shower?

A 10-minute shower can take 25 to 50 gallons of water. High-flow shower heads allow a flow of 6 to 10 gallons a minute. Low-flow shower heads can cut the rate in half without reducing pressure.

Sampling Results

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Arsenic (ppb)	2012	10	0	1.1	0.951–1.1	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2012	2	2	0.0389	0.0364–0.0389	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chloramines (ppm)	2012	[4]	[4]	3.60	1.5–3.60	No	Water additive used to control microbes
Chlorite (ppm)	2012	1	0.8	0.42	0.42–0.81	No	By-product of drinking water disinfection
Fluoride (ppm)	2012	4	4	0.66	0.50–0.66	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAA]–Stage 1 (ppb)	2012	60	NA	23.6	23.6–27.8	No	By-product of drinking water disinfection
Nitrate (ppm)	2012	10	10	1.04	0.08–1.04	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes]–Stage 1 (ppb)	2012	80	NA	43.6	37.3–43.6	No	By-product of drinking water disinfection
Turbidity ¹ (NTU)	2012	TT=1	NA	0.62	0.3–0.62	No	Soil runoff

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90TH% TILE)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	TYPICAL SOURCE
Copper (ppm)	2012	1.3	1.3	0.668	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2012	15	0	1.64	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits

SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	SMCL	MCLG	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Sulfate (ppm)	2012	250	NA	75.7	59.9–75.7	No	Runoff/leaching from natural deposits; Industrial wastes

UNREGULATED SUBSTANCES²

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT DETECTED	RANGE LOW-HIGH	TYPICAL SOURCE
Bromodichloromethane (ppb)	2012	16.8	13.5–16.8	By-product of drinking water disinfection
Chloroform (ppb)	2012	18.6	17.2–18.6	By-product of drinking water disinfection
Dibromomethane (ppb)	2012	8.2	6.6–8.2	By-product of drinking water disinfection

¹Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of water quality and the effectiveness of disinfectants.

²Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. Secondary MCLs (SMCLs) are set to protect the odor, taste, and appearance of drinking water.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.